




CERTIFICATE FI 29101

Our Ref. 280285

Product	Installation conduit, pliable
Type	16, 20, 25
Trade mark	Wavin
Certificate Holder	Nordisk Wavin A/S Wavinvej 1, DK-8450 HAMMEL, DENMARK
Manufacturer	Nordisk Wavin A/S Wavinvej 1, DK-8450 HAMMEL, DENMARK
Technical information	Outer diameter 16 mm, 20 mm, 25 mm
Other information	Pliable corrugated conduits of ivory white insulating material. Non-flame propagating. Lead free PVC. Temperature range: -25°C / +60°C. Resistance to impact: 2J. Resistance to compression: 750N
The product is certified according to the following standard(s)	EN 61386-1:2008, EN 61386-22:2004 + A11:2010
Validity	This certificate is valid until 27 April 2020 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.
Directive information	The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.
Date of issue	27 April 2015
Signature	SGS Fimko Ltd  Sixten Lökfors Project Manager

This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 29101

Manufacturing sites

Nordisk Wavin A/S
Wavinvej 1, DK-8450 HAMMEL,
DENMARK

Additional information

The products have certificate 1412042 and test report no. 907777 issued by Intertek Semko AB in accordance with the Certification Service system.

Our ref. no.

280285-1